

CLEVELAND HOSE PACK



**DEPLOYMENT AND BUNDLING
PROCEDURES**

Cleveland Hose Pack Deployment



- Hold first bundle securely with one hand
- Hold until bundle is placed on ground



- Release top buckle



- Release bottom buckle

Deployment continued...



- Place both hands on bundle with thumbs, split bundle in the middle



- Place bundle neatly on ground
- straighten bundle from horseshoe position



- Spread hose apart from middle creating a circle
- **Make sure** male and female couplings **do not** get wrapped around hose

Deployment continued...



- Line tender grabs both couplings
- Male from center
- Female from outside



- Nozzle person receives male coupling from new bundle
- Line tender receives male coupling from last section of fire fighting hose



- Connections made
- Call for water

Deployment continued...



- Charge line



- Bundle will expand with minimal kinks



- Immediate water to nozzle
- Advance line

Bundling Procedures



- Stretch 100' of 1 1/2" hose in a straight line



- Begin folding at male coupling. Fold hose inside 4'.



- Continue folding hose for entire length

Bundling continued...



- Bend hose around knee to form a horse shoe, pull tight to expel air



- First bundle is ready for pack



- Lay pack on ground with all straps loosened

Bundling continued...



- First bundle secured by black straps
- Make sure bottom strap has bundle supports in place



- Second bundle secured by orange straps



- Third bundle secured by yellow strap
- Make sure bottom strap has bundle supports in place

Bundling continued...



- 300ft of Hot Line 1 1/2" single jacket light weight hose secured to a Cleveland hose pack



- This pack weighs 47lbs.
- The old style "Delta Pack" weighs 53lbs with only 200ft of 1 1/2" single jacket cotton hose